## Water Testing Results - Post High Action Level is 15 parts per billion (ppb)

Action Level is 13 hai is her billion (hhp)			
Fixture Location/Description	Fixture ID #	Test Date	Test Result
Restroom Sink Faucet	21900700-001BF	4/5/23	ND
Kitchen Sink Faucet	21900700-002KF	4/5/23	ND
Refrigerator Water Outlet	21900700-003KF	4/5/23	ND
Any fixture testing at or above the action level of 15 ppb is immediately removed from service			
and cannot be returned to service until it has been remediated and passed follow-up testing			
RETESTS			
			_
ND = Non Detect - Lead level is below the set detection limits of X ppb			