

Water Testing Results - Oakdale Elementary

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Kitchen Sink Faucet (new 2018)	21900100-001KF	4/17/23	ND
Kitchen Sink Faucet (new 2018)	21900100-002KF	4/17/23	ND
Kitchen Sink Faucet (new 2018)	21900100-003KF	4/17/23	2.55
Kitchen Soup Pot (new sink2018)	21900100-004KF	4/17/23	ND
Music Room Sink Faucet (rm#20)	21900100-005CF	4/18/23	1.44
Music Room Drinking Fountain (rm#20)	21900100-006DW	4/18/23	ND
Gym Drinking Fountain (new 2018)	21900100-007DW	4/17/23	ND
Rm19 Sink Faucet (Rm#22)	21900100-008CF	4/19/23	6.14
Rm19 Drinking Fountain (Rm#22)	21900100-009DW	Fixture N/A	
Rm19 Sink Faucet (Rm#22)	21900100-010CF	4/19/23	16.5
Rm1 Sink Faucet	21900100-011CF	4/19/23	4.36
Rm1 Drinking Fountain	21900100-012DW	4/19/23	1.48
Rm2 Sink Faucet	21900100-013CF	4/19/23	9.41
Rm2 Drinking Fountain	21900100-014DW	4/19/23	4.7
Rm3 Sink Faucet	21900100-015CF	4/19/23	6.65
Rm3 Drinking Fountain	21900100-016DW	4/19/23	5.41
Rm4 Sink Faucet	21900100-017CF	4/19/23	3.62
Rm4 Drinking Fountain	21900100-018DW	4/19/23	3.43
Rm5 Sink faucet	21900100-019CF	4/19/23	26.7
Rm5 Drinking Fountain	21900100-020DW	4/19/23	6.46
Rm6 Sink Faucet	21900100-021CF	4/19/23	7.5
Rm6 Drinking Fountain	21900100-022DW	4/19/23	21.2
Rm5/6 Sink Faucet	21900100-023CF	4/19/23	17.4
Hallway Drinking Fountain #1	21900100-024DW	4/19/23	ND
Rm7 Sink Faucet	21900100-025CF	4/19/23	3.4
Rm7 Drinking Fountain	21900100-026DW	4/19/23	2.71
Rm8 Sink Faucet	21900100-027CF	4/19/23	2.47
Rm8 Drinking Fountain	21900100-028DW	4/19/23	8.04

Rm 8/9 Sink Faucet	21900100-029CF	4/19/23	4.64
Rm. 9 Sink Fountain	21900100-030CF	4/19/23	1.56
Rm. 9 Drinking Fountain	21900100-031DW	4/19/23	1.3
Rm. 10 Sink Faucet	21900100-032CF	4/19/23	2.72
Rm. 10 Drinking Fountain	21900100-033DW	4/19/23	1.72
Rm. 10/11	21900100-034CF	4/19/23	1.44
Rm. 11 Sink Faucet	21900100-035CF	4/19/23	6.99
Rm. 11 Drinking Fountain	21900100-036DW	4/19/23	4.22
Rm. 12 Sink Faucet	21900100-037CF	4/19/23	2.26
Rm. 12 Drinking Fountian	21900100-038DW	4/19/23	1.08
Rm. 13 Sink Faucet	21900100-039CF	4/19/23	9.87
Rm. 13 Drinking Fountain	21900100-040DW	4/19/23	27.1
Rm. 14 Sink Faucet	21900100-041CF	4/19/23	8.41
Rm. 14 Drinking Fountain	21900100-042DW	4/19/23	12.8
Rm. 14/15 Sink Faucet	21900100-043CF	4/19/23	16
Rm. 15 Sink Faucet	21900100-044CF	4/19/23	12.9
Rm. 15 Drinking Fountain	21900100-045DW	4/19/23	8.41
Rm. 16 Sink Faucet	21900100-046CF	4/19/23	28.4
Rm. 16 Drinking Fountain	21900100-047DW	4/19/23	ND
Rm . 16/17 Sink Faucet	21900100-048CF	4/19/23	5.53
Hallway Drinking Fountain #2	21900100-049DW	4/19/23	ND
Rm. 18 Sink Faucet	21900100-050CF	4/19/23	4.85
Rm. 18 Drinking Fountain	21900100-051DW	4/19/23	5.65
Library Sink Faucet (Work Room)	21900100-052CF	4/18/23	13.1
Health Rm. Sink Faucet	21900100-053CF	4/18/23	1.84
Faculty Lounge Sink Faucet	21900100-054SF	4/18/23	13.9
Facilty Restroom	21900100-055BF	4/18/23	ND
Faculty Restroom	21900100-056BF	4/18/23	4.41
Girls Restroom	21900100-057BF	4/18/23	1.35
Girls Restroom	21900100-058BF	4/18/23	3.82
Girls Restroom	21900100-059BF	4/18/23	1.07
Boys Restroom	21900100-060BF	4/18/23	5.91
Boys Restroom	21900100-061BF	4/18/23	1

Boys Restroom	21900100-062BF	4/18/23	1
Girls Restroom Sink Faucet	21900100-063BF	4/18/23	ND
Girls Restroom Sink Faucet	21900100-064BF	4/18/23	ND
Girls Restroom Sink Faucet	21900100-065BF	4/18/23	ND
Boys Restroom Sink Faucet	21900100-066BF	4/18/23	ND
Boys Restroom Sink Faucet	21900100-067BF	4/18/23	ND
Boys Restroom Sink Faucet	21900100-068BF	4/18/23	ND
Girls Restroom Sink Faucet	21900100-069BF	Fixture N/A	
Girls Restroom Sink Faucet	21900100-070BF	Fixture N/A	
Boys Restroom Sink Faucet	21900100-071BF	Fixture N/A	
Boys Restroom Sink Faucet	21900100-072BF	Fixture N/A	
Kitchen - Sink Faucet	21900100-073KF	Fixture N/A	
Kitchen - Soup Pot	21900100-074KF	Fixture N/A	
Music Room - Sink Faucet	21900100-075CF	Fixture N/A	
Classroom 19 - Sink Faucet	21900100-076SF	Fixture N/A	
Classroom 13 - Sink Faucet	21900100-077SF	Fixture N/A	
Classroom 12 - Drinking Fountain	21900100-078DW	Fixture N/A	
Classroom 16 - 17 - Sink Faucet	21900100-079CF	Fixture N/A	
Kitchen Sink Faucet (new 2018)	21900100-080KF	4/17/23	ND
Kitchen Sink Faucet (new 2018)	21900100-081KF	4/17/23	ND
MPR sink	21900100-082KF	4/17/23	ND
MPR Drinking fountain	21900100-083DF	4/17/23	ND
MPR Drinking fountain	21900100-084DF	4/17/23	ND
MPR Bottle fill	21900100-085WB	4/18/23	ND
Gym Bottle fill	21900100-086WB	4/18/23	ND
Gym Drinking Fountain	21900100-087DF	4/18/23	ND
Custodial closet mop sink	21900100-088SF	4/18/23	ND
Boys restroom gym hall	21900100-089BF	4/18/23	ND
Boys restroom gym hall	21900100-090BF	4/18/23	ND
Boys restroom gym hall	21900100-091BF	4/18/23	ND
Girls restroom gym hall	21900100-092BF	4/18/23	ND
Girls restroom gym hall	21900100-093BF	4/18/23	ND
Girls restroom gym hall	21900100-094BF	4/18/23	ND

Restroom gym hall	21900100-095BF	4/18/23	ND
Sick room faucet	21900100-096BF	4/18/23	1.56
Sick room faucet	21900100-097BF	4/18/23	4.53
Rm#22 sink faucet	21900100-098SF	4/19/23	ND
Rm#22 restroom	21900100-099BF	4/19/23	ND
Hallway Drinking Fountain #1B	21900100-100DW	4/19/23	ND
Hallway Bottle Fill #1C	21900100-101WB	4/19/23	ND
Hallway Drinking Fountain #2B	21900100-102DW	4/19/23	ND
Hallway Bottle Fill #2C	21900100-103DW	4/19/23	ND
Classroom 17 - Sink Faucet	21900100-104SF	4/19/23	4.77
Classroom 17 drinking Fountain	21900100-105DW	4/19/23	8.63
Classroom 21 sink faucet	21900100-106SF	4/19/23	3.53
Classroom 21 Drinking Fountain	21900100-107DW	4/19/23	1.73

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing

RETESTS	21900100-10CFB	6/15/23	ND
Rm19 Sink Faucet (Rm#22)	21900100-019CFB	6/15/23	ND
Rm5 Sink faucet	2190100-022DWB	6/15/23	2.16
Rm6 Drinking Fountain	21900100-023CFB	6/15/23	4.98
Rm5/6 Sink Faucet	21900100-046CF	6/15/23	ND
Rm. 16 Sink Faucet			

ND = Non Detect - Lead level is below the set detection limits of 1 ppb