

Water Testing Results - Lyle Elementary

Action Level is 15 parts per billion (ppb)

Fixture Location/Description	Fixture ID #	Test Date	Test Result
Kitchen Sink Faucet (new 2018)	21900200-01KF	4/27/23	1.85
Kitchen Sink Faucet (new 2018)	21900200-02KF	4/27/23	ND
Kitchen Sink Faucet (new 2018)	21900200-03KF	4/27/23	ND
Kitchen Sink Faucet (new 2018)	21900200-04KF	4/27/23	5.33
Rm. 10 Sink Faucet	21900200-05CF	4/28/23	11.8
Rm. 11 Sink Faucet	21900200-06CF	4/28/23	9.44
Boy's Restroom Sink Faucet	21900200-07BF	4/27/23	ND
Boy's Restroom Sink Faucet	21900200-08BF	4/27/23	ND
Boy's Restroom Sink Faucet	21900200-09BF	4/27/23	ND
Girls Restroom Sink Faucet	21900200-10BF	4/27/23	ND
Girls Restroom Sink Faucet	21900200-11BF	4/27/23	ND
Girls Restroom Sink Faucet	21900200-12BF	4/27/23	ND
Hallway Drinking Fountain #1 (Chilled)	21900200-13WC	4/27/23	ND
Rm. 12 Sink Faucet	21900200-14CF	4/28/23	2.54
Rm. 12 Drinking Fountain	21900200-15DW	4/28/23	2.33
Rm. 13 Sink Faucet	21900200-16CF	4/28/23	3.55
Rm. 13 Restroom Sink Faucet	21900200-17BF	4/28/23	1.19
Rm. 14 Sink Faucet	21900200-18CF	4/28/23	5.29
Rm. 15 Sink Faucet	21900200-19CF	4/28/23	9.65
Rm. 15 Drinking Fountain	21900200-20DW	4/28/23	7.24
Rm. 16 Sink Faucet	21900200-21CF	4/28/23	1.97
Rm. 16 Drinking Fountain	21900200-22DW	4/28/23	6.67
Rm. 17 Sink Faucet	21900200-23CF	4/28/23	8.47
Rm. 17 Drinking Fountain	21900200-24DW	4/28/23	7.41
Rm. 18 Sink Faucet	21900200-25CF	4/28/23	8.45
Rm. 18 Drinking Fountain	21900200-26DW	4/28/23	5.35
Hallway Drinking Fountain #2	21900200-27DW	Non op 4/27/23	

Hallway Sink Faucet #1	21900200-28CF	4/28/23	11.7
Princpal's Restroom Sink Faucet	21900200-29BF	4/27/23	2.76
Media Center Sink Faucet	21900200-30CF	4/27/23	ND
Rm. 1 Sink Faucet	21900200-31CF	4/28/23	18
Hallway Drinking Fountain #3 (chilled)	21900200-32DW	4/27/23	ND
Hallway Water Bottle Refill #1 (chilled)	21900200-33WC	4/27/23	ND
Hallway Drinking Fountain #4 (chilled)	21900200-34DW	4/27/23	ND
Boy's Restroom Sink Faucet	21900200-35BF	4/27/23	1.28
Boy's Restroom Sink Faucet	21900200-36BF	4/27/23	1.34
Boy's Restroom Sink Faucet	21900200-37BF	4/27/23	16.2
Girls Restroom Sink Faucet	21900200-38BF	4/27/23	4.48
Girls Restroom Sink Faucet	21900200-39BF	4/27/23	ND
Girls Restroom Sink Faucet	21900200-40BF	4/27/23	1.53
Rm. 2 Sink Faucet	21900200-41CF	4/28/23	10.5
Rm. 2 Drinking Fountain	21900200-42DW	Non op 4/28/23	5.61
Women's Restroom Sink Faucet	21900200-43BF	4/27/23	17.4
Mechanical Room Sink Faucet	21900200-44SF	4/27/23	ND
Hallway Drinking Fountain #5 (chilled)	21900200-45DW	5/1/23	ND
Hallway Drinking Fountain #6 (chilled)	21900200-46DW	5/1/23	ND
Hallway Water Bottle Refill #2 (chilled)	21900200-47WB	5/1/23	ND
Men's Restroom Sink Faucet	21900200-48BF	5/1/23	7.14
Rm. 3 Sink Faucet	21900200-49CF	4/28/23	6.29
Hallway Drinking Fountain #7 (chilled)	21900200-50DW	5/1/23	ND
Hallway Drinking Fountain #8 (chilled)	21900200-51DW	5/1/23	ND
Hallway Water Bottle Refill #3 (chilled)	21900200-52WB	5/1/23	ND
Rm. 4 Sink Faucet	21900200-53CF	4/28/23	9.6
Rm. 5 Sink Faucet	21900200-54CF	4/28/23	5.88
Rm. 5 Drinking Fountain	21900200-55DW	4/28/23	7.23
Boy's Restroom Sink Faucet	21900200-56BF	5/1/23	ND
Boy's Restroom Sink Faucet	21900200-57BF	5/1/23	ND
Boy's Restroom Sink Faucet	21900200-58BF	5/1/23	ND
Girls Restroom Sink Faucet	21900200-59BF	5/1/23	ND
Girls Restroom Sink Faucet	21900200-60BF	5/1/23	ND

Girls Restroom Sink Faucet	21900200-61BF	5/1/23	ND
Rm. 6 Sink Faucet	21900200-62CF	5/1/23	ND
Rm. 6 Drinking Fountain	21900200-63DW	Non op 5/1/23	
Rm. 8 Sink Faucet	21900200-64CF	5/1/23	ND
Rm. 8 Drinking Fountain	21900200-65DW	Non op 5/1/23	
Rm. 7 Sink Faucet	21900200-66CF	5/1/23	ND
Rm. 7 Drinking Fountain	21900200-67DW	Non op 5/1/23	
Rm. 9 Sink Faucet	21900200-68CF	5/1/23	ND
Rm. 9 Drinking Fountain	21900200-69DW	Non op 5/1/23	
East Modular Sink Faucet	21900200-70CF	5/1/23	10
Exterior Drinking Fountain (Playground)	21900200-71DW	Removed 2018	
Rm. 3 Sink Faucet	21900200-72CF	5/1/23	6.78
Rm. 4 Sink Faucet	21900200-73CF	5/1/23	16.4
Rm. 5 Sink Faucet	21900200-74CF	5/1/23	6.16
Kitchen Sink Faucet (new 2018)	21900200-75CF	4/27/23	ND
Kitchen Restroom Faucet (new 2018)	21900200-76BF	4/27/23	ND
MPR Girls Restroom	21900200-77BF	4/27/23	ND
MPR Girls Restroom	21900200-78BF	4/27/23	ND
MPR Unisex Restroom	21900200-79BF	4/27/23	ND
MPR Boys Restroom	21900200-80BF	4/27/23	ND
MPR Boys Restroom	21900200-81BF	4/27/23	ND
MPR Sink Faucet	21900200-82CF	4/27/23	ND
Staff lounge sink	21900200-83CF	4/27/23	5.3
Staff lounge Hot Tap	21900200-84CF	4/27/23	ND

Any fixture testing at or above the action level of 15 ppb is immediately removed from service and cannot be returned to service until it has been remediated and passed follow-up testing

RETESTS			
Boy's Restroom Sink Faucet	21900200-37BFB	6/15/23	2.5
Women's Restroom Sink Faucet	21900200-43BFB	6/15/23	5.77
Rm. 4 Sink Faucet	21900200-73BFB	6/15/23	5.4

ND = Non Detect - Lead level is below the set detection limits

of 1 ppb